

## NOTICE:

On Sunday May 17, 2020, from 6:10PM-11:10PM the Village of Waldo had a treatment facility overflow of approximately 21,000 gallons of untreated wastewater that was pumped from the influent manhole at the wastewater treatment plant unto a grassy area by the old wastewater treatment plant. It is possible that some of this wastewater may have flowed into the Onion River. The cause of the sanitary sewer overflow was 4.5 inches of precipitation in a 24 hour period. The pumps at the wastewater treatment plant could not handle the flow from the large rainfall event.

Bruce Neerhof : Village of Waldo Administrator