

RESOLUTION 2026-08-CMAR
VILLAGE OF WALDO

Wisconsin Department of Natural Resources
NR 208-Compliance Maintenance Resolution
Reporting year: 2025


WHEREAS, The Village of Waldo is required, under a Wisconsin Pollutant Discharge Elimination System (WPDES) permit issued by the Wisconsin Department of Natural Resources, to file a Compliance Maintenance Annual Report (CMAR) for its wastewater treatment and collection system pursuant to Wisconsin Administrative Code NR 208; and


WHEREAS, it is necessary for the governing body to acknowledge that it has reviewed the CMAR; and

WHEREAS, it is also necessary to provide recommendations or an action response plan for any individual CMAR section receiving a grade of "C" or lower and/or an overall grade point average below 3.00; and

WHEREAS, the Waldo Water & Sewer Utility achieved an overall grade point average (GPA) of 3.91 for the 2025 reporting year, receiving an "A" grade in all sections with the exception of a "B" grade in the Phosphorus section due to a single month exceeding the phosphorus limit caused by dry conditions and low dilution levels, which was promptly addressed and corrected for the remainder of the year;

NOW, THEREFORE, BE IT RESOLVED by the Village of Waldo Board of Trustees and the Waldo Water and Sewer Utility Board, that the wastewater treatment plant and collection system will continue to be maintained at a high level of performance.

Adopted this 8th day of June 2026, by the Village of Waldo Board of Trustees, Sheboygan County, Wisconsin  (Travis Thomas, President)

Confirmed this 8th day of June 2026, by the Waldo Water and Sewer Utilities, Sheboygan County, Wisconsin  (Travis Thomas, President)

ATTEST: 
Lisa Gillette-Clerk/Treasurer